

ELECTRICAL SAFETY RECALL

DC Isolating Switch

HGN4-32DC



IDENTIFICATION:

The part number HGN4-32DC is clearly marked on the side of the unit.

Only DC Isolating switches with the model number HGN4-32DC are affected

Units were installed between 7th October 2011 and 1st March 2014

HAZARD:

There is the potential risk of fire from faulty contacts within the internal mechanism of this switch

ACTION REQUIRED:

Consumers should contact I Want Energy on 03 6234 7009 if they suspect they have this switch installed. The faulty switches will be replaced at no cost to the customer.

For further information

Please direct all calls and any queries concerning this recall to the
office@iwantenergy.com.au

See www.recalls.gov.au for Australian product recall information